

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO: 7270-1582:101

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Chemetronics, 400 Main Street, Ashland, MA 01721
Contact: Terrill Garland (508) 881-2000

DESIGN: Models 501, 502, 503 and 504 heat detectors. Models with suffix WPB-M are suitable for outdoor use. Models with suffix EPB are equipped with explosion proof box. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 136° F and 190° F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, temperature rating and UL label.

APPROVAL: Listed as heat detectors for use with separately listed compatible fire alarm control units.

NOTE: Formerly 7270-0061:002

10-30-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 13, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager